
VOLUME 2

TECHNICAL SPECIFICATIONS (Rev.1)

TENDER DOCUMENT -

**SUPPLY INSTALLATION, TESTING & COMMISSIONING OF HYDROPNEUMATIC
SYSTEMS, WTP, PUMPS, VALVES & FLOW METERS WORKS
FOR PROPOSED PERMANENT CAMPUS (PHASE I)
FOR
INDIAN INSTITUTE OF MANAGEMENT UDAIPUR, AT VILLAGE BALICHA,
UDAIPUR.**

Item 1.0 : Hydro-pneumatic system

Supply, installation, testing & commissioning of Hydro-pneumatic system with vertical inline Multistage booster centrifugal SS - 316L pump-motor sets, suitable for operation on 415 volts, 50 Hz, 3 phase AC supply, with 500 Ltrs pneumatic balancing tank, mounting skid, foot valves, G.I. suction & discharge pipes, fittings, cast brass / virgin brass valves, C.I. Strainers at suction head, etc. Each pump shall have TEFC 1450 / 2900 RPM three phase electric motor. The scope includes pressure switches, VFD based control panel with starters, protections, relays, cables, interlocking with level & pressure switches. Suction / Delivery Piping all connections, etc complete for domestic supply only. Panel to be compatible to MODBUS IP, with the adequate I/O.

SCOPE (Item Description)

The item includes the Pumps (Vertical/Horizontal centrifugal type), Pressure vessels, pressure switches, gauges, pressure transmitter on delivery manifold, pump suction & delivery piping, manifolds & valves, flexible bellows, Fixed speed/variable frequency drive, control panels, Microprocessor based operation) and all accessories including installation, testing & commissioning.

PUMP-MOTOR SET

DESIGN & CONSTRUCTION FEATURES

Two types of pumps i.e. inline vertical multistage or horizontal type centrifugal pump shall be provided. Variable frequency drive shall be provided with one of the installed pump – if specified in Schedule of quantity.

The pump motor set shall be suitable for 3 Ph., 415 V, 50 Hz. AC power supply and having 1500/ 2900 RPM speed. The pump shall be installed with isolation gate/ butterfly valve, non return valve, etc. The detailed specification for pump & motor is as below :

The design and manufacture of the pump shall comply with all currently applicable statutes, regulations and safety codes in the locality where the equipment will be installed.

The pump shall be capable of developing required total head at rated capacity. Impeller shall be closed type and shall be dynamically balanced. The pump shall have non overloading characteristics.

The casing shall be of rigid construction and shall have side suction and side delivery in case of vertical multistage pump and side suction and central delivery in case of horizontal centrifugal pump.

The pump shall have very small length suction and delivery pipe connections which will result in minimum friction loss.

Impeller shall be of one piece and shall be of SS CF8 M.

The shaft shall be of S.S. and its surface shall be properly finished.

Shaft sleeves shall be provided to protect shaft from any damage.

Bearing shall be ball or roller type.

Mechanical seal shall be provided to avoid any leakage.

Pump shall be mounted on a concrete foundation, projecting at least 15 CM above finished floor level. The pumps base shall be set on an anti vibration pad.

All the parts of the pumps that are in contact with water e.g. shaft, impeller etc. shall be hot dip galvanized or of stainless steel construction.

Pumps shall be so selected that the design duty point is within 5% of the maximum efficiency point. Shut off head shall be 120% of duty point head.

All pumps and motors shall be of minimum vibration and noise level during operation. Vibration isolators shall be provided for all pump sets.

Facilities shall be provided to prevent starting of pumps when the water tank is at low water level. An indicator for this low water level alarm shall be provided.

Facilities to select which pump to be duty pump and standby pump shall be provided and be interchangeable.

Leakage from pump gland shall be drained to the nearest floor waste.

Pump shall be driven by directly coupled squirrel cage induction motor having TEFC enclosure, IP 55 protection & shall be of Class F insulation.

Pump motors above 7.5 kW shall be equipped with a spacer coupling which allows changing of shaft seals without removing the motor.

INSPECTION & TESTING

The pump shall be offered for visual inspection before dispatch.

Material test certificates for the various pump components shall be furnished for purchaser's approval.

SYSTEM DESCRIPTION

The system operation will be such that the initial small water demand shall be met by the charged diaphragm pressure vessel. When the water demand continues the system pressure will dip to a preset pump cut-in point when the lead pump starts to operate at reduced speed through the variable speed drive. However, if the system pressure be still below the pre-set value, the controller continuously increases pump speed to meet the system demand. When the lead pump is not able to meet the system pressure at full speed, the second pump also starts to operate.

At peak demand all the pumps operate, similarly, if there is a drop in water demand the duty pump speed starts to reduce, then standby pumps cuts-off, followed by stopping of the duty pump.

The closed diaphragm pressure vessel shall be of polyethylene material with a pressure gauge and isolating valve. The interior shall be of non-toxic lining suitable for use with potable water. The vessel shall be manufactured to conform to ASME pressure vessel code/standards.

The system shall be under the control of a microprocessor based control panel.

A pressure transmitter shall detect the pressure at the delivery manifold and feedback to the microprocessor control panel via control circuit.

The system shall incorporate a frequency converter or frequency converter motors on the pumps and the pressure transmitter shall register the actual pressure on the discharge side.

The variable frequency drive pumping system shall maintain a constant pressure regardless of the system demand. If there is a drop in pressure outside the preset point, the Variable Frequency Drive (VFD) pump shall start to run until the pressure increases to the preset limit, or it will continue to increase the pump speeds to the upper limit of the frequency. If the water system demand still cannot be met, the second pump shall be called in to run, the VFD will then alter the pump speed to meet the preset pressure point. If the set point is still unable to be met, the third pump is then activated to run (in case of 3 pumps units).

This shall be achieved by continuously varying the motor speed of the duty pump according to the demand up to a maximum designed capacity.

Under decreasing hydraulic demand the reverse sequence to the above description shall apply. Alternatively pumping system shall be with fixed speed drive motor. By getting the signal from microprocessor based control panel through pressure transmitter, pumps will operate in sequence & vice versa.

The frequency converter shall be linked to the motor of the duty pump for continuous speed adjustment and ultimately the water delivery shall be maintained at constant pressure at the pre-set value.

CONTROL PANEL

The motor control panel shall be equipped with all the necessary electrical components including a microprocessor control unit and a frequency drive. The control panel and the microprocessor shall cover the following functions.

Flexibility and simplicity in allowing the necessary re-adjustment of the pumping system pre-set delivery pressure to operate the pumps within the specified maximum and minimum delivery ranges.

Automatic changeover of the pumps to be controlled by the microprocessor which dictates the duty and standby pumps.

When the system has not been operated for more than 24 hours, it shall automatically start the pumps for a few seconds/day to ensure the pumps readiness at all times. The standby pumps shall be activated upon failure of duty pump(s).

In event of control failure, the pumps shall be able to be start/stopped manually at the local panel by means of pressure switches.

The microprocessor control panel shall be able to cut-off the pumping system when excess pressure is registered in the discharge common manifold.

The system shall have the capability of receiving input signal concerning reduced water level in suction tanks and shall have control mechanism to prevent the pumps from running dry.

Automatically starting the pumps when the water level is back to normal.

In case of pump failure due to motor overload, the standby pump is switched on automatically. Alarm signal is displayed on the LCD Display unit and alarm lights are activated.

Functions to limit the no. of start/stop of pumps per hour.

The system control panel shall incorporate LCD Display.

OPERATION OF CONTROL PANEL

Auto mode

The desired delivery pressure within the range specified, shall be set at the control panel. The pressure transmitter shall detect the delivery pressure continuously and give feedback to the microprocessor which will control the variable speed drive frequency converter for speed control of the duty pump. When demand increases, the subsequent pumps in the system will be activated to boost up the pressure. Ultimately the duty pump set shall be operated fully automatically to maintain the delivery pressure constantly at the desired set value.

Manual Mode

The on/off function of the pumps shall be manually adjusted at the microprocessor located at the local control panel.

Frequency Control By-pass Mode

All the pumpsets shall be started/stopped automatically with the pump output at fixed maximum rotational speed. All the control and protection functions shall remain active. The cut in/cut out pressure shall be internally calculated by the microprocessor for each pump.

ELECTRICAL COMPONENT

All circuit breakers, thermal overloads and contactors shall be of reputable make acceptable to the architect. Electrical supply to the pump controller shall be protected using an isolating circuit breaker.

METHOD OF STARTING

The panel shall be built to start the pumps in suitable starting modes, i.e. D.O.L., Star/Delta, or using Soft Starters.

PUMP PRESSURE VESSEL

Diaphragm type pressure vessels shall be provided as shown on the drawings. They shall be incorporated into the system so that during normal operation the pump shall not need to be start within 30 seconds of it switching off in order to prevent the pump hunting.

The pressure vessel shall be of adequate capacity to accommodate a considerable fluctuation in water demand by the system with minimum start/ stop cycles of the pumps. The vessel shall be constructed of steel plate built to ASME standards for Unfired Pressure Vessel. A rubber diaphragm shall be provided in the vessel for separating the water and pre-charge nitrogen. The pre-charge pressure shall be adjustable and charging port with non-return device shall be provided. The adjustable cut-in and cut-off pressure unit for the pumps shall be built-in at the vessel to suit the system.

ACCESSORIES

The system shall be provided with all accessories such as base plate, mounting pads, foundation bolts, foot valves, pressure gauge, pressure switches, pressure transmitter, level indicator, isolation valve for pressure vessel, etc. all accessories required for proper and safe operation shall be furnished with the pumps.

SUCTION AND DELIVERY PIPE, FITTINGS, FLANGES & VALVES

All suction, delivery and header pipe shall be GI & shall conform to IS: 1239, medium/heavy duty. Fittings shall be as per the pipe thickness. All pipes shall have flanges connection & pipe shall conform to BS 10, Table - D. All hardware shall be zinc plated. The system shall be equipped with suction & delivery valves/flanged valves. On suction side ball/gate valve shall be provided while on delivery side ball/butterfly valves shall be provided. Also, spring operated check valve shall be provided on delivery side of each pump & on delivery header. In case of negative suction foot valve shall be provided for each pump suction or suction header as specified in data sheet. Flexible bellows shall be provided on suction & delivery side of each pump.

TESTING

Hydrostatic test shall be carried out at 1.5 times the maximum discharge pressure.

For electrical accessories, necessary tests shall be performed or factory test certificate shall be furnished.

DRAWINGS

Following drawings shall be furnished by the vendor:

Overall dimensional drawing.

Pump performance curves..

Cross-sectional drawings.

Panel GA drawing.

Bill of Material and Material of Construction.

TECHNICAL DATA SHEET FOR HYDRO PNEUMATIC SYSTEM

SR.	PARTICULAR	SPECIFICATIONS
1.0	SYSTEM :	
1.1	Application	Domestic / Flushing water
1.2	System capacity	50 M ³ /Hr
1.3	System head	105 / 65 / 80 Meters
1.4	Operating hrs.	4 hrs.
1.5	Location	Pump Room
2.0	PRESSURE VESSEL	
2.1	Capacity	As per BOQ
2.2	No. of Unit	As per BOQ
2.3	Material of Construction	M.S. conforming to IS 2062 / FRP
2.4	Shell thickness	8 mm / Suitable for 8 Kg/cm ² pressure rating.
2.5	Dished end thickness	10 mm/ Suitable for 10 Kg/cm ² pressure rating.
2.6	Test Pressure	10 kg / cm ² minimum
2.7	Painting	Epoxy
2.8	Type of Air Compressor	Oil free, Teflon coated / Inbuilt Air cell
2.9	Tank outlet size	As per Manufacture's configuration
3.0	PUMPS	
3.1	Type	Vertical Multistage/ Horizontal centrifugal
3.2	Number of Units	As per BOQ
3.3	Design capacity / pump	As per BOQ
3.4	Total head at design capacity	As per BOQ
3.5	Suction Pressure at rated capacity (NPSHa)	Positive Suction
3.6	Speed	1500 / 2900 RPM
3.7	PUMP - FEATURE OF CONSTRUCTION	
3.7.1	Impeller	Closed
3.7.2	Shaft	Coupled
3.7.3	Drive Transmission	Direct
3.7.4	Seal	Gland Packing
3.7.5	Mounting	Common base plate
3.7.6	No. of stage	Single
3.7.7	Starter	DOL / VFD
3.7.8	Flange drilling	As per BS 10, Table D, flat face with off centre bolt holes
3.8	PUMP - MATERIAL OF CONSTRUCTION	
3.8.1	Base plate	M.S. IS 226
3.8.2	Pump Casing	SS /C.I.

SR.	PARTICULAR	SPECIFICATIONS
3.8.3	Impeller	SS CF 8 M
3.8.4	Shaft	S.S AISI 410
3.8.5	Wearing Ring	SS 316
3.8.6	Painting	Epoxy
3.8.7	Hardware in contact with water	Hot dipped galvanized
3.8.8	Companion flanges	M.S., BS 10, Table D
4.0	INDUCTION MOTOR	
4.1	Type	Squirrel cage Induction
4.2	Mfg. Standard	IS 325
4.3	Rated Voltage	415 Volts, 3 Phase, 50 Hz., AC
4.4	Voltage and frequency variation	± 10% voltage variation ± 5% frequency variation ± 10% combined voltage and frequency variation
4.5	Speed in RPM	1500/2900 RPM
4.6	Class of Insulation	Class B
4.7	Degree of Protection	IP 55
5.0	ACCESSORIES & SERVICES REQUIRED	
5.1	Base Plate	YES
5.2	Foundation bolts	YES
5.3	Companion flanges	YES
5.4	Spare parts required	YES
5.5	Maintenance tools required	YES
5.6	Mounting anti vibration pads	YES
5.7	Pressure Gauges	YES, on delivery of each pump & on delivery header
5.8	Pressure Switches	YES, on delivery of each pump & on delivery header
5.9	Foot Valve	Yes in case of negative suction
6.0	Suction & delivery piping	GI Class B / C as specified in BOQ
7.0	Suction, delivery valves & header valves	Required, flanged Cast Iron valves with SS internal parts Flanged Ball / Gate valve on suction and Flanged Ball / Butterfly valve on delivery of each pump & Flanged Non slam, spring operated dual plate type check valve on delivery side of each pump & on header Flexible bellows on suction & delivery side of each pump
8.0	Control Panel	DOL/Star Delta / With VFD (if specified in BOQ) Power / control cable from starter to pump to be provided

SR.	PARTICULAR	SPECIFICATIONS
9.0	Level Indicator	Required for 0-5 mtr. Range and shall be panel mounted and interlocking with pump
10.0	Hardware	Zinc coated

RATES

Pump-Motor sets.

Pressure vessel with isolation valves.

Base plate, foundation bolts, anti vibration pads.

Pump suction – delivery pipe & suction & delivery manifolds.

Foot valves in case of negative suction.

Pump Suction isolation valve, Pump delivery & delivery manifold isolation valve &NRV, suction manifold isolation valve, pump suction & delivery flexible bellows.

Pressure gauges, switches & panel mounted Pressure transmitter, level indicator to be interlocked with pump operation.

Microprocessor based control panel with all electrical components, protections, interlocks, cable from control panel to pump.

Variable frequency drive/drives if called in BOQ.

All electrical accessories.

All material like flanges, hardware, gaskets, etc. required for installation.

Installation, testing & commissioning.

Making all damage good to original condition after completion of work.

All necessary labor, material and use of tools.

MODE OF MEASUREMENT

The measurement shall be for one set or one job

MODE OF PAYMENT

The contract rate shall be for one set or one job

Item NO. 2 Water Treatment Plant

Supply, Installation, Testing and Commissioning of Self Cleansing Hydraulic Filter having powder coated S.S. / Carbon Steel / C. I. Body with the following details:

TECHNICAL SPECIFICATIONS

Inlet/outlet Diameter	150Ø (6")mm
Min./Max. Working Pressure	3 Bar / 10 Bar
Fluid Maximum Temperature	50 °c
Maximum Inlet Water TSS	200 mg/l (200ppm)

Stainlesssteel Screen Data

Maximum Flow Rate (m ³ /h)	15 / 50
Gross Filtering Surface (cm ²)	5300
Net Filtering Surface (cm ²)	4390
Unladen Weight	88
Filtration Degree	15 / 50 microns

Backwashing Data

Backwashing Valve	G-1" Thread
Backwashing Cycle time	15-20 second
Backwashing Flow Rate (m ³ /h)	9
Backwashing Water Consumption(l)	50-55

Electric Data

Supply voltage	220 V AC 50 Hz Single-phase (Optional 400 V AC Three-phase and 12 V DC)
Control voltage	24 V DC (12 V DC supply 12 V DC)
Electric motor power	0.18 kW
Electric motor consumption	0.72 A

Standard Materials

Filter housing and lids	S-235-JR carbon steel
Finish treatment	Kiln Polymerized epoxy-polyester powder coating
Suction scanner	AISI-304 stainless steel
Filtration screen	AISI-316 stainless steel
Suction nozzles	PVC with AISI 316 stainless steel ring and nylon brushes
Backwashing vavles	Polypropylene

MODE OF MEASUREMENT

The measurement shall be for one set.

MODE OF PAYMENT

The contract rate shall be for one set.

**Item 3.0 Supply, installation, testing and commissioning of monoblock centrifugal pump. Each pump shall have TEFC 1450 / 2900 RPM single / three phase electric motor. The pump shall have CI body, and casing ring, SS 316-L impeller, SS 410 Shaft and shaft sleeve, coupling guard, common base plate, foundation bolts, etc Pumps shall be provided with mechanical seal. The pump shall be suitable for auto / manual operation. Including coupling guard, common base plate, foundation bolts, etc and with all accessories and to be provided & to extract water from the reservoir and transfer to filtration system and distribution of filtered water to terrace storage water coolers at each hostel cluster. 1 Set of pumps includes the following:
15 Cum / Hr**

SCOPE (Item Description)

This specification covers the supply, installation; testing & commissioning of Horizontal Centrifugal type (Monoset)/ Openwell monoset submersible pumps. The scope also includes motor, delivery piping upto Discharge Header with necessary pipe, fittings, electric panel, pressure gauges, etc. Each pump shall have isolation gate/ ball valve & NRV at delivery side & on header.

CODES AND STANDARDS

The design and manufacture of the pump shall comply with all currently applicable statutes, regulations and safety codes in the locality where the equipment will be installed.

DESIGN FEATURES:

The pump shall be capable of developing required total head at rated capacity.

Impeller shall be enclosed type and shall be dynamically balanced.

The pump shall have non overloading characteristics.

The pump shall be submerged in reservoir.

CONSTRUCTIONAL FEATURES

The casing shall be of rigid construction and shall have central delivery pipe.

The casing shall be of Cast Iron.

The pump shall have very small length suction and delivery pipe connections which will result in minimum friction loss in case of monoset pumps.

Impeller shall be of one piece and shall be of SS CF 8 M.

The shaft shall be of S.S. and its surface shall be properly finished.

Shaft sleeves shall be provided to protect shaft from any damage.

Bearing shall be ball or roller type.

Mechanical seal shall be provided to avoid any leakage.

Each pump shall be driven by directly coupled squirrel cage induction motor having 1500/2900 RPM, TEFC enclosure & IP 55 protection.

INSPECTION AND TESTING

The pump shall be offered for visual inspection before dispatch.

Material test certificates for the various pump components shall be furnished for purchaser's approval.

Hydrostatic test shall be carried out at 1.5 times the maximum discharge pressure.

For electrical accessories, necessary tests shall be performed or factory test certificate shall be furnished.

DRAWINGS:

Following drawings shall be furnished by the vendor.

Overall dimensional drawing.

Cross-sectional drawings with Bill of Material and Material of Construction.

Pump performance curve.

TECHNICAL SPECIFICATIONS FOR CENTRIFUGAL MONOSET SUBMERSIBLE PUMPS

SR.	PARTICULAR	SPECIFICATIONS
1.0	Application	Water Transfer
2.0	Number of Units	As per BOQ
3.0	Design capacity of each pump	As per BOQ
4.0	Total head at design capacity	As per BOQ
5.0	Total duration of operation	As per BOQ
6.0	Speed	1500 RPM
7.0	Location	Inside the tank
8.0	FEATURE OF CONSTRUCTION	
8.1	Impeller	Enclosed
8.2	Shaft	Coupled
8.3	Drive Transmission	Direct
8.4	Seal	Mechanical
8.5	Mounting	Base plate
8.6	No. of stage	Single
8.7	Nozzle orientation A. Suction B. Discharge	Side suction Top discharge
8.8	Starter	DOL for upto 5 KW & Star / Delta

		for more than 5 KW rating
8.9	Flange drilling	As per BS 10, Table F, raised face with off center bolt holes
9.0	LIQUID DATA	
9.1	Liquid handled	Water
9.2	Specific gravity	1.0
9.3	Temperature	Ambient temp.
10.0	MATERIAL OF CONSTRUCTION	
10.1	Base plate	M.S. IS 226
10.2	Pump Casing	Cast Iron
10.3	Impeller	SS316
10.4	Shaft	S.S AISI 410
10.5	Wearing Ring	S.S AISI 410
10.6	Painting	Epoxy
10.7	Hardware in contact with water	Hot dipped galvanized
10.8	Companion flanges	M.S., BS 10, Table F
11.0	ACCESSORIES & SERVICES REQUIRED	
11.1	Base Plate	YES
11.2	Foundation bolts	YES
11.3	Companion flanges	YES
11.4	Spare parts required	YES
11.5	Maintenance tools required	YES
11.6	Foot valves	Required in case of negative suction
12.0	MOTOR :	
12.1	Power Supply	230 / 415 Volts, 3 phase, 50 Hz. AC
12.2	Class of Insulation	Class B
12.3	Degree of Protection	IP 55
13.0	Delivery piping	GI, Class `B`/C
14.0	Delivery valves & header valves	flanged valves Flanged Ball / gate valve on delivery side of each pump & Flanged Non Return Valve on delivery side of each pump & on header Flexible bellows on delivery of each pump
15.0	Starter Panel	Required with pump interlocking with respect to tank levels. Power / control cable from starter to pump to be provided
16.0	Level Indicator	Required for 0-5mtr. Range and shall be panel mounted and interlocking with pump.
17.0	Pressure Gauge	Required at delivery of each

		pump & on header. 0 –7 kg/sq.cm
--	--	------------------------------------

RATES

Pump-Motor sets.
 Base plate, foundation bolts, anti vibration pads.
 Pump delivery pipe & delivery manifolds.
 Foot valves in case of negative suction.
 Pump delivery & delivery manifold isolation valve &NRV & delivery flexiblebellows.
 Pressure gauges& level indicator to be interlocked with pump operation.
 Starter panel with all electrical components, protections, interlocks, cable fromstarter to pump.
 All material like flanges, hardware, gaskets, etc. required for installation.
 Installation, testing & commissioning.
 Making all damage good to original condition after completion of work.
 All necessary labor, material and use of tools.

MODE OF MEASUREMENT

The measurement shall be for one set including working & stand by units

MODE OF PAYMENT

The contract rate shall be for one set including working & stand by units

Item 4.0- Water Level Indicators.

Water level indicators cum controllers working on hydrostatic pressure measurement principle made of Stainless Steel for installation on storage tanks, and capable of providing 4 to 20 mA analog signal compatible with PLC signal inputs, including all wiring and piping as required complete as per working requirements for details of equipment below. All control outputs to MCC panel shall be included as per requirements.

SCOPE (Item Description)

External cage magnetic float operated level switches for tanks and vessels Micro switch with 2 SPDT contacts rated for 5A, 240VAC / 0.25 A, 220 V DC. Material of float & float chord shall be 316 SS & cage material shall be fabricated steel and the material of accessories shall be SS. IP 65 or equivalent degree of protection for enclosure. Accessories like name plate, drain valve for external case type level switches, mating flange, gaskets (asbestos), fasteners, bolts & nuts, etc. shall be supplied. Conductivity type electronic

CODES AND STANDARDS

The design and manufacture of the pump shall comply with all currently applicable statutes, regulations and safety codes in the locality where the equipment will be installed.

TECHNICAL SPECIFICATIONS

Type :	Magnetic Internal Float operated.
Float, Stem & Wetted material :	SS 316
Switch Housing & Material :	Weather proof / Explosion proof IIC in Cast Aluminum / Custom housing for corrosive atmosphere.
Type of Contact :	Micro, 2 SPDT.
Rating :	10 A @ 250 V AC , 0.2 A @ 250 V DC / specified. .
Switch Differential :	12 ± 3 mm.
Conduit :	3/4" BS, 1/2" / 3/4" NPT
Pressure / Temperature:	15 - 40 kg/cm ² / 2000C.
Specific Gravity :	0.7 and above
Process Connection, Type :	1 1/2" and above, Screwed or Flanged
Float Size :	Ø 47 or 60 mm

INSTALLATION PROCEDURE

Drill a required diameter hole or provide sleeve into your tank at the marked location.

Install level indicator using the supplied accessories and check all fittings.

MODE OF MEASUREMENT

The measurement shall be for one set.

MODE OF PAYMENT

The contract rate shall be for one set.

Item 5.0 : Electronic Flow Meters

Providing & fixing on line turbine type flow meter with preamplifier & microprocessor based electronic flow meter mounted in plumbing plant room electrical control panel with the following features. Monitoring the total flow, Flow rate, high low arm batching and blending etc. Including electrical wiring from preamplifier to microprocessor based flow meter. Complete with all type of Plumbing & Electrical connections, accessories, wiring, conduits & supports complete with all respect. The signal from read out shall be 4-20 m.amps to be received on BAS.

TECHNICAL SPECIFICATION:

Principal	Turbine flow meter
Material:	
Body	Stainless Steel / Carbon Steel
Flange	Stainless Steel / Carbon Steel
Rotor	Stainless Steel / ANC21
Bearing Support	Stainless Steel
Bearing	Tungsten carbide, SS ball bearing

General:

Accuracy	Linearity (+/- 0.5% over 10% to 100% flow range) Repeatability (+/- 0.02% to 0.05% on 95% confidence level)
Temperature Range	-20°C to +150°C
Pressure Drop	4 PSI
Maximum Pressure	4000 PSI

MODE OF MEASUREMENT

The measurement shall be for one no.

MODE OF PAYMENT

The contract rate shall be for one no.

Item 6.0 : Pressure Release Valves

Providing, installation, testing and commissioning of Pressure Release Valves of following sizes complete in all respect as per technical specification and as per direction of Engineer.

Pressure Range: 0 to 10.0 kg/cm²; Accuracy: 0.1 - 0.5%;

MOC : Cast Iron for dia from 65mm to 100m

MOC: Brass for dia less than 65mm dia

Construction

The pressure reducing valve comprises:

- Housing with pressure gauge connection G1/4"
- Spring bonnet with adjustment opening
- Green adjustment knob
- Adjustment spring
- Pressure gauge not included (see accessories)

Materials

- Dezincification resistant brass housing
- High-quality synthetic material spring bonnet
- Spring steel adjustment spring
- NBR seals

Range of Application

Medium Water

Inlet pressure max. 16 bar

Outlet pressure 1.5-6 bar adjustable

Installation position Horizontal and vertical installation position possible

In vertical installation position spring

bonnet with adjustment knob facing upwards

Operating temperature max. 40°C accord. to DIN EN 1567 max. 70°C (max. operating pressure 10 bar)

Minimum pressure drop 1 bar

Connection size 3/8", 1/2", 3/4"

Method of Operation

Spring loaded pressure reducing valves operate by means of a force equalising system. The force of a piston operates against the force of an adjustment spring. If the outlet pressure and therefore piston force fall because water is drawn, the greater force of the spring causes the valve to open. The outlet pressure then increases until the forces between the piston and the spring are equal again. The inlet pressure has no influence in either opening or closing of the valve. Because of this, inlet pressure fluctuation does not influence the outlet pressure, thus providing inlet pressure balancing.

MODE OF MEASUREMENT

The measurement shall be for one no.

MODE OF PAYMENT

The contract rate shall be for one no.

Item no. 7 Hydraulic Self cleaning Filter with UV Filter

Supply, Installation, Testing and Commissioning of Self Cleansing Hydraulic Filter with electrical actuation and disinfection treatment by means of ultraviolet lamps having S.S.316 L Body with the following details

GENERAL DATA

Maximum flow (m³/h): 15; Inlet/Outlet diameter: 80 mm (3"); Maximum/minimum working pressure: 10 Bar / 3 Bar; Fluid maximum temperature: 40⁰ C; Filtration degrees: 25 microns; Maximum Inlet water TSS: up to 50 ppm

ELECTRICAL DATA

Rated operation voltage: 415 Volts AC 50 Hz three phase; Control voltage: 24V DC;

UV lamp : Low voltage amalgam, No. of Lamp : 4 nos, UVC : 50W, Dose : 400 J/m², Lamp cleaning motor /intensity :24 V DC/ 3A

Approved Makes: Gopani / Ion Exchan

Item 8.0 AIR VALVE

Providing and fixing C.I. double acting air valve of approved quality with bolts, nuts, rubber insertions etc. complete including the tail pieces, tapers etc if required including all the accessories and testing etc to the satisfaction of Engineer In Charge.

25mm Ø

SCOPE

The item includes supplying of single, double action or kinetic air Valve of specified diameter as mentioned in the schedule including fixing.

MATERIAL

Single air valve shall have single small or large orifice for releasing air during pipe filling and ventilating the pipe during emptying. Air valves up to 50 mm diameter directly shall be screwed on the main.

Double air valve shall have two ball chambers, on outlet of large capacity shall be provided for admission and release of bulk volume of air during emptying and filling of the main, another of small outlet type for the escape of smaller quantities of air accumulating under pressure. They shall be of flanged type.

Air valve body, bonnet, glands, caps, joints support rings shall be best gray iron of selected grade, 200 of IS-210-1978 specification for gray iron castings.

Ball guides of small orifice units and outlet bushes of large orifice valves shall be of gunmetal.

Nipples, spindles shall be machined from rolled, extruded or forged high tensile brass or aluminium bronze.

The balls shall be of rubber covered and vulcanite covered. The rubber shall have a smooth and hard surface. It shall be as per I.S. 638-1965 specification for rubber and insertion jointing.

Air valve shall be provided with isolation valve with IS certification mark and isolation valve.

FIXING

The Air Valve shall be fixed in position as indicated in the drawing or as directed. They shall be fitted by means of flange joints or screwed joint to the pipe line.

TESTING

The Air Valve and the joints shall be tested hydraulically to a minimum pressure of 10 kg/cm² or 1.5 times working pressure whichever is greater for minimum 4hrs without any leakage.

RATES

Supplying and fixing Air Valve of specified diameter and type with isolation valve.

Fixing & Jointing material & specials.

Painting.

Making all damage good to original condition after completion of installation work.

Testing & commissioning

All necessary materials, labor and use of tools.

MODE OF MEASUREMENT

The measurement shall be for each unit of Air Valve fixed.

MODE OF PAYMENT

The contract rate shall be for each unit of air valve fixed.

Item 9.0 PRESSURE GAUGE

Providing, installation, testing and commissioning of glycerin filled Pressure gauge of 16KG pressure range with isolation valve and tap off pipe complete in all respect as per technical specification and as per direction of Engineer.

SCOPE

The item includes provision of Pressure Gauge of specified range as mentioned in the schedule with siphon tubing & SS isolation cock.

MATERIAL

The pressure gauge shall be constructed of die cast aluminium and stove enameled.

It shall be weather proof with an IP 55 enclosure.

It shall be a stainless steel Bourdon tube type pressure gauge with a scale range from 0 to 16 Kg/cm² and shall be constructed as per IS:3524.

Each pressure gauge shall have a siphon tube connection. The shut off arrangement shall be by SS Ball Valve.

FIXING

It shall be fixed vertically in position on pipe line by means of screwed nipple, spool piece or as required or as directed by the Engineer-in-charge.

TEST

Calibration certificate shall be obtained and submitted for each pressure gauge.

RATES

Pressure Gauge with isolation valve & siphon tubing.

Making connection with piping with all accessories.

Making all damage good to original condition after completion of installation work.

Testing the entire system and rectification of defects if any.

All necessary materials, labor and use of tools.

MODE OF MEASUREMENT

The measurement shall be for each unit of Pressure Gauge of specified range fixed.

MODE OF PAYMENT

The contract rate shall be for each unit Pressure Gauge of specified range fixed.

