

PRE-BID QUERIES & CLARIFICATIONS

Name of Work :-Supply, Installation, testing and Commissioning of Kitchen Equipment Works for Proposed Permanent Campus (phase 1), IIM Udaipur at Balicha village

Tender Ref no.: IIMU/E1/2017/1

S.NO.	Reference	Page no.	Query	IIMU clarification
1	M/s Krist Engg. & Mfg. Corp. their mail dated 24th April 3.59 p.m.			
1.1			We further request you to please consider our query (if any), we send through email before the opening of Tender	No further queries will be entertained.
2	M/s Bharti Refrigeration Works Their mail dated on 24th April at 5.08 p.m.			
2.1	Sl. No. 4. Period of Completion - 24 days	Page 8 of NIT	The completion of time including of every thing like submission of shop drawings, approval of shop drawings, installation, testing and commissioning and obtaining completion certificate is given very less that is only 24 days. Which does not look justified in view of voluminous work. It is recommending that atleast 6 to 8 weeks.	The period of completion shall stand revised to 45 days from the date of Letter of Award and the Delivery & commissioning dates shall be as given below: Delivery Schedule: Each equipment shall get delivered within the number of days as specified in the revised BOQ attached hereto. These number of days indicated in the modified BOQ is considered from the date of Letter of award Installation, Testing and Commissioning of all equipment Shall be completed within 45 days from the date of Letter of Award.
2.2	Sl. No. 3 Earnest Money Deposit: clause 8	Page 8 & 12 of NIT	We are registered vendor under NSIC and MSME so we wish to clarify whether we are exempted from submission of EMD.	It is not applicable to this Tender and the bidders shall submit Earnest Money Deposit as specified in the NIT document.
2.3			Please whether whether non-judicial stamp paper can be bought from Delhi	Non-judicial stamp paper of any State/ Union Territory of India may be used.
2.4	Cluse 7	Page 12 of NIT document	We would like to clarify since our registration for Digital Signature is under class 3 so please clarify whether it is valid or not for the Tender participation because as per Tender instruction it says that intending tenderers are advised to obtain valid class-II (or appropriate) digital signature to participate in Tendering.	Class - III Digital Signature will serve our purpose
2.5	S.no. - K-51; K-94; K-95	Refer BOQ	We recommend that all refrigerators should be customised because there has always been a lot of service and spare parts related problems with the imported refrigerators.	It can be customised but the the following specifications must be adhered to: 4 door refrigerator. make-custom REFRIGERATOR-1300 Ltr. Temperature +2 to +8 deg C, Inner and outer in SS Panel Incorporated Digital Temperature Controller, Electronic Auto Defrost, static Cooling, 3 SS shelves/Slides for gastronorms PUF INJECTED Insulation - 50mm Drip Tray, Power 750 Watts kirloskar Compressor Unit,SS Adjustable Legs 6" high ,D/S -1200 x 750 x 2100mm 2 door refrigerator- Inner and outer in SS make-custom REFRIGERATOR-600 Ltr. Temperature +2 to +8 deg C PUF INJECTED Insulation - 50mm Panel incorporated Digital Temperature Controller, Electronic Auto Defrost, static Cooling, 3 SS shelves/Slides for gastronorms SS Adjustable Legs 6" high Drip Tray, Power 400 Watts kirloskar Compressor Unit Doors, Shelf Closing, with magnetic gasket with lock key, flushed handle D/S - 750 x 750 x 2100mm
2.6	S.No. - K-112 Dish Washer	Refer BOQ	The specification for the item no. K-112 i.e. Dish washer in the BOQ list matches with the specification of conveyor type dish washer not the hood type. Please clarify whether you want to go for Hood type dish washer or conveyor type dish washer.	Only Hood type Dish washer will be installed and commissioned. The technical specification for Hood type dish washer shall be as given below - MAKE-Electrolux , Model-EHTROW505054/ OR winter halter Height-hoodclosed - 1520mm,Rack size(square) - 500mm Maximum plates per rack-18,Maximum clear entry height-385mm Operating level - <70db,Net weight - 83 kg,Shipping weight - 95 kg,Shipping dimensions,Weight - 850mm Depth - 800mm,Height - 1470mm,Built in air gap (water council approved - WRC) - Yes Rinse booster pump- Yes,Built in detergent dispenser Optional Built in rinse aid dispenser - Optional Maximum racks per hour - 60 Cycle times - short program 1 min+ long,program 2 min Water connection BSP - 3/4" Water inlet height from floor level, Gravity drain- 0-300mm Water pressure - 1-6 bar,Water flow - 4.8ltr/min. Drain height from ,floor level - Gravity drain 0-300mm Drain size - 45mm parameter Operating voltywse - 400V/50Hz/3phase,Amps required, 3 ph per phase - 19,Total connected load -12.85kw Wash tank geating - 4.35 kw,Rinse boiler heating - 26 kw Wash tank capacity - 39 ltr,Wash tank operating Temperature - 55°c,Rinse boiler capacity - 7 ltr Rinse boiler operating ,Temperaturew - 65 & 80°c Per cycle - 2.8 ltr
2.7	S.No. K-84	Refer BOQ	Please clarify whether you would require fire suppression for the exhaust hoods because you have not mentioned it against item no. K-84.	Fire suppression system,is required with the exhaust hood. K-66 SS Exhaust Hood With Baffle Filters, Fresh Air Grill & Fire Suppression System Size of 5500X2600X600 K-83 SS Exhaust Hood With Baffle Filters, Fresh Air Grill & Fire SuppreSsion System .these are 2 in numbers out of which only one will have the fire suppression system.
2.8	Last date of submission and opening of Tender	Sl. No. 7 Page 8 of NIT Document	We request you to kindly extend the submission and opening time of the tender in view of forthcoming holidays like Saturday, Sunday and May 1st Labour day these three consecutive holidays would keep entire work hampered. Hence you are requested to extend the submission and opening time and date be extended for atleast four to five days.	The last date of submission and opneing of Tender shall stand revised to 8th May 2017 upto 1600 Hours.