

PRE-BID QUERIES & CLARIFICATIONS

Name of Work: SUPPLY AND INSTALLATION OF UPVC WINDOWS FOR PROPOSED PERMANENT CAMPUS (PHASE I) FOR INDIAN INSTITUTE OF MANAGEMENT UDAIPUR, AT VILLAGE BALICHA, UDAIPUR

Tender Ref no. IIMU/uPVC WINDOWS/2017-18/12/2

S.NO.	Reference	Page no.	Query	IIMU clarification
1	Profile Thickness		The uPVC profile thickness is mentioned as 2.8mm , according to the bidders the maximum available is 2.5mm thick only	The thickness of profile extrusions shall be minimum 2.5 mm
2	Specification for the fly mesh to be used in the openable windows		SS mesh is to be used in the fly mesh shutter, but the grade of SS (whether SS304 etc.) is not mentioned. Also SS Black or SS ordinary to be used	stainless steel grade 304 wire gauge with wire of dia 0.50 mm and average width of aperture 1.4 mm in both directions shall be used.
3	Specification of the Glass to be used as "infill glass" in the openable windows	-	The specification of the glass to be used as "infill glass" in the openable shutter is not mentioned i.e. the thickness of the Glass etc.	All glass shall be Low E Glass equivalent to Saint Gobain ET-125 and shall be 6 mm thick.
4	Fixing arrangement of Sash for the fixed protion in windows	-	The sash for the "fixed glass" is to be fixed from outside, this may lead to theft problem, can it be changed to inside?	Sash of fixed glass to be fixed from inside.